Water Operators Report Feb. 2025

Prepared by: Dave Shepherd

| Water consumption | | | | | | | |
|-------------------------------|-----------------------|-----|------------------|-----------------------|----|---------------|-----------|
| Monthly Consumption | 5274.5 M ³ | | 28 | 363.68 M ³ | | Daily Average | |
| Previous year 2024-Feb | 4287 M ³ | | 28 | 338.04 M ³ | | Daily Average | |
| | | | | <u>7.59%</u> | | | |
| Vol Well #1 since 19 Jan 2019 | 350.87 M ³ | | | | | Last month | Last year |
| Max Flow for month | 1,115.60 L/Mi | n | Min Flow for mo | nth L/Min | 12 | 0 | 18.6 |
| Time and Date | 08/02/2025 07:28 | | 01/02/2025 11:56 | | | | |
| Pump hours | # 2 | 685 | # 3 | 0 | #4 | 23 | |
| Previous month hrs | | 669 | | 1 | | 3 | |

| VIHA Samples | | | | | | | |
|------------------------|------------|----------------|----------------|--------------|------|---------------------------------|--|
| Activity | Date | Location | Sample type | Result | | | |
| Monthly | 24/02/2025 | 7941 Park | Drinking water | \checkmark | | | |
| Sample /testing | | 7588 Ships Pt. | Drinking water | \checkmark | ⋖ | | |
| | | 7576 Tozer | Drinking water | \checkmark | VIHA | | |
| | Well 2 | Raw | \checkmark | t to | | | |
| | | Well 3 | Raw | X | Sent | Not recorded over winter months | |
| | | Well 4 | Raw | \checkmark | • • | | |
| Operations/Maintenance | | | | | | | |

Weekly:

Meter readings, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data Check CL tank level and add accordingly

Monthly:

Prep chain of custody report and sample bottles Collect Island Health samples and deliver to office Collect end of month Data create report, replace CL membrane & order chlorine as needed Attend WTC and SPID Meetings

03/02/2025 Call out Cnr SPR/Baynes unusual water patch in middle of intersection the concern Frozen/split pipe
After visiting site I found out that a salt truck dumped a large amount in this spot.

04/02/2025 BC 1 Call SPR/ Victor lane, Address on SPR access on Victor! Sent pix of drawing

| 05/02/2025 | 3 Pumphouse fire extingushers inspected (one was replaced) and returned to Pump house |
|------------|--|
| 07/02/2025 | BC 1 call Tozer locate section on drawing and send pix, clean up G drive and delete files |
| 09/02/2025 | Call out Tozer water shooting up above house, confirmed, no one home looked for contact info |
| 10/02/2025 | Check on Tozer leak, no longer cans see or hear from road (assumed fixed) |
| 11/02/2025 | Flow rate higher than expected, Knocked on Tozer Rd door no anwser, noticed leak covered up |
| 12/02/2025 | Deliver repair notice to Tozer rd. |
| 14/02/2025 | Gain access to Tozer rd. service box by cutting blackberry and digging down 6" to enable repair/shut off |
| 15/02/2025 | Change from CL pump #2 to CL pump #1, Tozer Rd. leak has been repaired |
| 16/02/2025 | Call out Baynes, leak under house, no one living there, shut water off and informed owner |
| 19/02/2025 | Sent email to Gord (Simpson Maxwell) re Generator full load test. He will call when up this way |
| 24/02/2025 | IH messed up with sample delivery to Lab so had to re sample and take to IH office |
| 27/02/2025 | Request for price from SPID for plumber to move service box off SPR Drive |