

Water Operators Report Jan. 2025

Prepared by: Dave Shepherd

Water consumption

Monthly Consumption	4188.41 M ³	28	363.68 M ³	Daily Average	
Previous year 2023-12	4280 M ³	28	338.04 M ³	Daily Average	
			<u>7.59%</u>		
Vol Well #1 since 19 Jan 2019	346.98 M ³			Last month	Last year
Max Flow for month	1,836.90 L/Min	Min Flow for month L/Min	0	3.4	13.6
Time and Date	11/01/2025 10:58		21/01/2024 04:35		
Pump hours	# 2 669	# 3 1	#4 3		
Previous month hrs	669	1	3		

VIHA Samples

Activity	Date	Location	Sample type	Result	
Monthly	13/01/2025	7941 Park	Drinking water	✓	
Sample /testing		7588 Ships Pt.	Drinking water	✓	Sent to VIHA
		7576 Tozer	Drinking water	✓	
		Well 2	Raw	✓	
		Well 3	Raw	☒	
		Well 4	Raw	✓	
					Not recorded over winter months

Operations/Maintenance

Weekly:

Meter readings, CL residuals (5 locations) incl flushing station, run pump 1 collect well levels data
Check CL tank level and add accordingly

Monthly:

Prep chain of custody report and sample bottles Collect Island Health samples and deliver to office
Collect end of month Data create report, replace CL membrane & order chlorine as needed
Attend WTC and SPID Meetings

05/01/2025 Water works inventory

06/01/2025 Return CL pump #2 4:20 settings back to 4=0 form 4= 0.1 re flow meter working at low flow

08/01/2025 Zip remaining files on G Drive and download

11/01/2025 Call out re leak, SPR, large leak observed on home owners property, I located the service box and recommended
They contact a plumber

13/01/2025 Generator test with JL

15/01/2025 Comm's with Rob (White Pacific) they have downloaded "Any Desk" to our Pumphouse Laptop and cant gain access
I went in to Control panel and changed sleep time from 15min to never

17/01/2025 review 2024 for IH annual report, request IH monthly samples results July to Dec 2024

22/01/2025 Took Pumphouse fire extinguishers to Fire hall for annual inspection (contractor)

23/01/2025 Back up G Drive files "OG's" to sync, tried and failed to extract zipped files!!
Zip and Download individual Gdrive folders to Laptop then upload to sync then delete G Drive files

29/01/2025 Complete IH annual report and send to IH (save copy to Sync)

30/01/2025 Email from Tozer road resident re concerns of water quality (comms with JA re a response)
Concerns 1) low pH, 2) increasing CL 3) Lead

31/01/2025 edit response to Tozer resident re water quality concerns